

EMERGENCY KIT INSPECTION FORM

Serial # _____ Next Inspection: _____

Kit Location: _____

It is recommended that all Emergency Kit owners establish and practice an inspection and training program on a regular basis. Kits should be inspected to ensure that the equipment is complete and ready for emergency use. Kits include contents lists, date stamped gaskets and box seals to assist inspection programs. Kit owners often coordinate routine kit inspections with training exercises. This form is provided as a convenient record of inspections and equipment expirations. Please contact Indian Springs Mfg. for further information.

Viton Gasket Recommended Shelf-Life Expiration - 4 yrs. (Date stamp is date of manufacture):

√	QTY.	PART #	DESCRIPTION	NOTES
	1	1A2	Hood Assembly (with Vent Valve 1V)	
	2	1BRV	Gasket, Molded from Viton®	
	1	1C1	Yoke	
	1	1D1	Cap Screw	
	3	1K1	Cap Screw	
	1	1EFP	Base Assembly (with Chains 1F)	
	1	1R	Ramp	
	1	2	Clamp Assembly (with Block 2A, Yoke 2C, Set Screw 2D)	
	5	2B	Gasket, 15/16" dia. x 1/16" thick	
	5	2BB	Gasket, 1" x 3" x 1/16" thick	
	1	8A	Chain	
	1	8B	Yoke	
	1	8C	Cap Screw	
	1	8D	Steel Patch	
	2	8EV	Gasket, Molded from Viton®, 3" sq. x 1/8" thick	
	1	200A	Wrench, 3/8" sq. box, 1-1/4" open end x 7-1/4" long	
	1	201	Wrench, straight open end, 1-1/4" x 1-1/8" x 12-1/8" long	
	1	203	Wrench, combination, 7/16" x 7-1/4" long	
	1	A-1	Hammer, machinist 3 lb.	
	1	A-2	Hacksaw, 10" and 3 blades	
	2	A-3	Drift Pin, 9/32" x 1/2" x 6" long	
	2	A-4	Drift Pin 7/8" x 1-1/4" x 8" long	
	5	A-5	Ring, vent valve packing, 7/8" OD x 15/32" ID x 1/4" thick	
	15	A-6	Kit Box Seals	
	1	A-7	Gasket Sack	
	1	A-8	Paint Scraper	
	1	A-9	Valve Yoke	
	1	A-10	Valve Adapter	
	5	A-12	Washer, valve outlet, 15/16" OD" x 9/16" ID X 1/16" thick	
	1	A-13	Plastic Box	
	1	A-14	File	
	1	144	Tool Roll	
	1	151A	Kit Box	
	2	IA	Instruction Booklet	
	1	CM	Chlorine Manual	

Viton® is a registered Trademark of DuPont Dow Elastomers

10/22/08

Inspected by: _____ Date: _____ Kit Seal: _____